

Certificate of Compliance

This certificate is issued for the following:

Anti-Water Hammer Check Valves Air Release Valves

(see attached configuration table)

Prepared for:

DeZurik-APCO 250 Riverside Ave North Sartell, MN 56377

FM Approvals Class: 1230 (December 2013), 1344 (January 2010)

Approval Identification: PR452067

Superseded by: RR220202

Superseded by: RR221082

Superseded by: RR221947

Superseded by: RR223162

Date Approved: October 7, 2019

Date Approved: December 10, 2019

Date Approved: February 5, 2020

Date Approved: April 22, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

FM Approvals®

Member of the FM Global Group

David B. Fuller

VP, Manager of Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA



Certificate of Compliance

Anti-Water Hammer Check Valves

CSC 300A, CSC 600A

| Product Designation | Valve Size, in. | Flow Rate,gal/min (dm³/min) | Friction Loss, psi (kPa) | Rated Working Pressure, psi (kPa) | |
|------------------------|--------------------|--------------------------------|-----------------------------|--------------------------------------|--|
| CSC 300A | 4 | 750 (2840) | 9.8 (67.5) | 250 (1725) | |
| CSC 300A | 6 | 1500 (5680) | 6.5 (45.0) | 250 (1725) | |
| CSC 300A | 8 | 3000 (11 355) | 8.2 (56.5) | 250 (1725) | |
| CSC 300A | 10 | 5000 (18 925) | 9.3 (64.0) | 250 (1725) | |
| CSC 600A | 4 | 750 (2840) | 7.4 (51.0) | 250 (1725) | |
| CSC 600A | 6 | 1500 (5680) | 5.7 (39.5) | 250 (1725) | |
| CSC 600A | 8 | 3000 (11 355) | 7.4 (51.0) | 250 (1725) | |
| CSC 600A | 10 | 5000 (18 925) | 8.5 (58.5) | 250 (1725) | |
| CSC 600A | 12 | 7000 (26 500) | 8.0 (55.0) | 250 (1725) | |



Member of the FM Global Group



Certificate of Compliance

Air Release Valves

ARV-50A-R332, ARV-55-R332, ARV-50A-R116

| Product Designation | Size, in. (mm) | Orifice Diameter, in. (mm) | Pressure Rating psi (kPa) | Remarks |
|------------------------|-------------------|-------------------------------|---------------------------------|---------|
| ARV-50A-R332 | 1/2 (13) | 3/32 (2) | 175 (1205) | а |
| | 3⁄4 (19) | 3/32 (2) | | |
| | 1 (25) | 3/32 (2) | | |
| ARV-50A-R116 | 1/2 (13) | 1/16 (2) | 300 (2070) | а |
| | 3⁄4 (19) | 1/16 (2) | | |
| | 1 (25) | 1⁄16 (2) | | |
| ARV-55-R332 | 1/2 (13) | 3/32 (2) | 175 (1205) | а |

Remarks:

a. Valve supplied with a female NPT inlet end connection and a 1/2 inch female NPT outlet connection.



Member of the FM Global Group